



# District water testing laboratory, U.P Jal Nigam, Kanpur Nagar



Inside U.P Jal Nigam store house, 100 F, H-Block, Near  
ashok Kalia House, Gujaini, Kanpur Nagar. Pin- 208022

7561920301

## Drinking water sample test report

### User Information

Name: shatrughna shingh

Full address: House No- ,Village- ,Gram Panchayat- ,Block- ,District- ,State- UTTAR  
PRADESH

Mobile: 7355753240

Email: sshatrughan51@gmail.com

Source of Sample: Tube well / Bore well



U15963L359S242101

## Water sample test results

Date & Time of Sample Collection- 2021-06-16 13:00:45

Report Generation Date- 2021-06-23 15:17:17

Date & Time of Sample Received- 2021-06-17 12:00:38

Sr.	Parameters tested	Unit of measurement	Requirement (Acceptable Limit)	Permissible limit in absence of alternate source	Test Result value	Remarks
1	pH	NA	6.5-8.5	No Relaxation	7.39	
2	TDS	Milligram/liter	500	2000	554.2	
3	Turbidity	NTU	1	5	0.64	
4	Fluoride (as F)	Milligram/liter	1	1.5	0.033	

5	Conductivity	micromhos per centimeter / microsiemens per centimeter	NA	NA	1108
6	Total Alkalinity (as Calcium Carbonate)	Milligram/liter	200	600	444
7	Chloride (as Cl)	Milligram/liter	250	1000	188
8	Total Hardness (As CaCO <sub>3</sub> )	Milligram/liter	200	600	500


**Results approved by**  
Archana kumari

**Note:** This is an auto generated report no signature required

**Designed & developed by BMI Division @ICMR. Copyright © NJJM 2020**

स्वास्थ्य सफाई एवम स्वच्छ पेय जल प्रमाण पत्र

प्रमाणित किया जाता है कि 'विन्यास पब्लिक स्कूल' ग्राम अमिलिहा ब्लाक चौबेपुर कानपुर नगर में पेयजल की व्यवस्था सुदृढ एवम मानकीकृत है। शौचालय एवम सीवेज की व्यवस्था भी स्वास्थ्य की दृष्टि से उत्तम एवम सन्तोषजनक है।



स्वास्थ्य अधिकारी  
ब्लाक चौबेपुर  
कानपुर नगर

  
SHAIKHA VALI  
PRINCIPAL  
VINYAAS PUBLIC SCHOOL  
AMILIHA, CHAUBEPUR  
KANPUR

VARUN KATIYAR  
MANAGER  
VINYAAS PUBLIC SCHOOL  
AMILIHA, CHAUBEPUR  
KANPUR